

# Zeal Education Society's ZEAL POLYTECHNIC, PUNE. NARHE | PUNE -41 | INDIA

# THIRD YEAR (TY)

# DIPLOMA IN ELECTRICAL ENGINEERING SCHEME: I SEMESTER: V

NAME OF SUBJECT: ILLUMINATION & ELECTRIFICATION OF BUIDINGS

Subject Code: 22530

**MSBTE QUESTION PAPERS & MODEL ANSWERS** 

**1. MSBTE SAMPLE QUESTION PAPER** 

**2.MSBTE WINTER-19 EXAMINATION** 

# Scheme – I

# **Sample Question Paper**

Program Name	: Electrical Engineering Program Group	
Program Code	: EE/EP/EU	22520
Semester	: Fifth	22530
<b>Course Title</b>	: Illumination and Electrification of Buildings	(Elective)
Max. Marks	: 70	Time: 3 Hrs.

#### **Instructions:**

- (1) All questions are compulsory.
- (2) Illustrate your answers with neat sketches wherever necessary.
- (3) Figures to the right indicate full marks.
- (4) Sub-questions in a main question carry equal marks.
- (5) Assume suitable data if necessary.
- (6) Preferably, write the answers in sequential order.

### Q.1) Attempt any five of the following.

- a) State different types of electronic dimmers available for illumination control.
- b) Compare the salient features of mercury vapour lamp and sodium vapour lamp based

on (i) lamp efficiency (ii) lumen output

- c) State the different types of arc lamps.
- d) State any two methods used for light control.
- e) Explain the concept of photometry.
- f) State the recommended illumination level for

i) library and (ii) operation theatre.

g) Name any two lamps used in video films.

#### Q.2) Attempt any three of the following.

- a) State any four effects that can be obtained by lighting on stages.
- b) Illustrate with neat wiring diagram a single lamp control by two point method.
- c) Explain the working of HID lamp.
- d) State the factors to be considered while selecting a lamp for a particular application.

#### Q.3) Attempt any three of the following.

- a) Write any four safety measures and precautions to be followed for a special purpose lamp.
- b) Explain the working of fluorescent lamp.
- c) Write any four design considerations for illumination scheme of industrial premises.
- d) Explain the working principle of transformer dimmers with the help of a neat sketch.

12 Marks

**10 Marks** 

#### Q.4) Attempt any Three of the following.

2

- a) Select illumination level required as per ISI for following working plane in residential building i) kitchen, ii) living room, iii)dining room and iv)study room.
- b) Explain lighting scheme to be designed for each of following i) operation theatre in hospital and ii) general ward in hospitals.
- c) Analyze effects of variation of supply voltage on performance of CFL, as regards current, lumen output, efficacy and life.
- d) State the purpose of lighting control. List different types of dimmers. Explain any two dimmers with suitable diagrams.
- e) Explain with a neat diagram "flood lighting".

# Q.5) Attempt any Two of the following.

- a) Classify different lighting calculation methods and explain any one.
- b) Estimate the total number of lamps required for a living room of a residence having area 16m x 10m.Assume utilization factor of 0.8, maintenance factor of 0.8 and lumens output of each lamp of 1500.
- c) State importance of light house in shipyards and describe the working of the light house illumination system.

# Q.6) Attempt any Two of the following.

- a) Explain the luminaries in operation theatre of a hospital and the lux level required.
- b) Explain control of a single lamp from four places. Draw relevant circuit diagram
- c) A uniform illumination of 150 lux is to be obtained on the floor of room measuring 15m x 15 m by arranging electric light suitably .Calculate no of lamps and wattage of each lamp if lamp efficiency is 20 lumens /watt .Assume and write suitable value of constants required for this calculation.

#### 12 Marks

# Scheme – I

# Sample Test Paper - I

Program Name	: Electrical Engineering Program Group	
Program Code	: EE/EP/EU	22520
Semester	: Fifth	22530
<b>Course Title</b>	: Illumination and Electrification of Buildings	(Elective)
Max. Marks	: 20	Time: 1 Hour

#### **Instructions:**

- (1) All questions are compulsory.
- (2) Illustrate your answers with neat sketches wherever necessary.
- (3) Figures to the right indicate full marks.
- (4) Sub-questions in a main question carry equal marks.
- (5) Assume suitable data if necessary.
- (6) Preferably, write the answers in sequential order.

### Q.1 Attempt any FOUR.

- a. Define following terms i) lux and ii) lumens.
- b. Write two uses of photometry.
- c. List any two applications of halogen lamps.
- d. State the factors considered for selection of mounting of florescent lamp in residential area.
- e. Design a control circuit for LED using atriac.
- f. State any two methods used for enhancing lighting control.

#### Q.2 Attempt any THREE.

a. For the figure shown below, answer the following:



i) Identify the curve (ii) State the type of the curve and (iii) Give its applications.

- b. Draw a neat labelled diagram of neon sign tube and explain its working.
- c. Give comparison between LED and CFL lamps. (Any four points).
- d. Explain the dimmer by using two winding transformer.
- e. Explain the different controlling methods for enhancing interior applications..

# 08 Marks

# Scheme – I

# Sample Test Paper - II

Program Name	: Electrical Engineering Program Group	
Program Code	: EE/EP/EU	22520
Semester	: Fifth	22530
<b>Course Title</b>	: Illumination and Electrification of Buildings	(Elective)
Max. Marks	: 20	Time: 1 Hour

#### **Instructions:**

- (1) All questions are compulsory.
- (2) Illustrate your answers with neat sketches wherever necessary.
- (3) Figures to the right indicate full marks.
- (4) Sub-questions in a main question carry equal marks.
- (5) Assume suitable data if necessary.
- (6) Preferably, write the answers in sequential order.

### Q.1 Attempt any FOUR.

- a. State any two objectives of design of street lighting.
- b. Write two factors to be taken into account while designing the Flood lighting.
- c. List the special purpose lamps used in photography.
- d. State any two differences between uniform lighting and localised lighting.
- e. State any two applications of decorative lighting..
- f. Name any two lamps with their ratings used in horticulture.

#### Q.2 Attempt any THREE.

- a. State the possible location of mounting a projector in flood lighting with a neat sketch.
- b. Explain the general principles employed in the design of street lighting.
- c. Design an illumination scheme for a workshop with an area of 80 x 20 m in size. Assume a suitable space height ratio, utilisation factor, and depreciation factor. Consider a lamp efficiency of 20 lumens / watt.
- d. Identify the figure. Label its parts and state its working.



#### **08 Marks**

e. Identify the lamp and label its parts.



# 22530

# 11920 3 Hours / 70 Marks

Seat No.

*Instructions* : (1) All Questions are *compulsory*.

- (2) Illustrate your answers with neat sketches wherever necessary.
- (3) Figures to the right indicate full marks.
- (4) Assume suitable data, if necessary.
- (5) Write any special instructions if any. Preferably write the answers in sequential order.

		Mai	rks
1.	Atte	empt any FIVE of the following :	10
	(a)	Define Enhance lighting.	
	(b)	Compare the salient features of LED and CFL based on	
		(i) Lamp efficiency	
		(ii) Life span	
	(c)	Define the terms incandescent and incandescent lamp.	
	(d)	State two types of electronic dimmer.	
	(e)	State the first law of illumination.	
	(f)	State the Lux Level recommended for (1) Class Room (2) College Auditorium.	
	(g)	State any two type of lamps used in Horticulture.	
2.	Atte	empt any THREE of the following :	12
	(a)	Explain the features of Aquarium lighting.	
	(b)	Illustrate with neat wiring diagram a single lamp control by two point method.	
	(c)	Explain the working of HPMV Lamp with neat diagram.	
	(d)	Compare the AC and DC Arc lamps.	
		[1 of 2] P.T	.0.

# **3.** Attempt any THREE of the following :

- (a) Explain the working of Neon sign tube with diagram.
- (b) State the selection criterion of the lamp for various purposes.
- (c) State any four design considerations for illumination scheme of commercial complex.
- (d) Describe the working principle of Thyristor operated dimmer with the help of circuit diagram.

# 4. Attempt any THREE of the following :

- (a) Select the illumination level required as per ISI for following working plane in residential building :
  - (i) Kitchen sink
  - (ii) Staircase
  - (iii) Dining room
  - (iv) Study room
- (b) Explain the lighting scheme to be designed for each of the following :
  - (i) Special ward in hospitals
  - (ii) Dentist's cabin
- (c) Analyse the effect of supply voltage on performance of LED, as regards current, Lumen output, efficacy and life.
- (d) State the purpose of light control. List the different types of dimmer.
- (e) State the different types of outdoor flood lighting and where are they used ?

# 5. Attempt any TWO of the following :

- (a) State the various lighting calculations method and describe any one of them.
- (b) A workshop measures  $10 \text{ m} \times 25 \text{ m}$ . The shop is illuminated by 24 lamps of 200 watts each. The lumen efficiency of each lamp is 15 lumens per watt. Depreciation factor is assumed to be 0.8 and a co-efficient of utilisation 0.5. Determine the illumination on the working plane.
- (c) State the requirements of illumination scheme of shipyard.

# 6. Attempt any TWO of the following :

- (a) Enlist the luminaries used in factory lighting and lux level required in various areas.
- (b) Describe control of a single lamp from three places. Draw the relevant circuit diagram.
- (c) A drawing hall 30 metres by 15 metres with a ceiling height of 5 metres is to be provided with a general illumination of 120 lumens per metres square ; taking a co-efficient of utilization of 0.5 and depreciation factor of 1.4. Determine the number of fluorescent tubes required, their spacing, mounting height and total wattage. Take luminous efficiency of fluorescent tube as 40 lumens per watt for 80 watt tubes.

12

12

12

12



# Winter – 2019 Examinations <u>Model Answers</u> Subject & Code: Illumination and Electrification of Buildings (22530)

Important Instructions to examiners:

- 1) The answers should be examined by key words and not as word-to-word as given in the model answer scheme.
- 2) The model answer and the answer written by candidate may vary but the examiner may try to assess the understanding level of the candidate.
- 3) The language errors such as grammatical, spelling errors should not be given more importance (Not applicable for subject English and Communication Skills).
- 4) While assessing figures, examiner may give credit for principal components indicated in the figure. The figures drawn by candidate and model answer may vary. The examiner may give credit for any equivalent figure drawn.
- 5) Credits may be given step wise for numerical problems. In some cases, the assumed constant values may vary and there may be some difference in the candidate's answers and model answer.
- 6) In case of some questions credit may be given by judgement on part of examiner of relevant answer based on candidate's understanding.
- 7) For programming language papers, credit may be given to any other program based on equivalent concept.

(Autonomous) (ISO/IEC-27001-2013 Certified)

MAHARASHTRA STATE BOARD OF TECHNICAL EDUCATION

# Winter – 2019 Examinations **Model Answers**

Subject & Code: Illumination and Electrification of Buildings (22530)

		<ul> <li>Enhance lighting intensity, used diamond and wa</li> </ul>	g is the lighting with variou for decoration and effec tches showroom purpose.	is colour effect and controlled light tive visualization of gold, silver,	correct definition
1	b)	Compare the salient feat i] Lamp Efficiency ii] Life span <b>Ans:</b>	tures of LED and CFL base	d on:	
		Parameter	LED	CFL	
		Lamp Efficiency	High (more than 70 lumen per watt)	Comparatively less (50-60 lumen per watt)	1 Mark for each
		Life span (in working hours)	10000	3000	parameter
1	c)	Define the terms incand Ans: Incandescent is the pho- heated. An incandescent lamp & light is created.	escent and incandescent lan enomenon in which the obj is a lamp in which the fila	np. ect emits or creates light when it is ment is heated by electrical current	1 Mark for each definition
1	d)	State two types of Elect Ans: Two types of electronic 1) S.C.R. operated dimme 2) Triac operated dimme	ronic dimmer. dimmers are: ner er		1 Mark for each
1	e)	State the first law of illumination. Ans: This law states that the illuminance (E) at any point on a plane perpendicular to the line joining the point and source is inversely proportional to the square of the distance between the source and plane. $E = \frac{1}{d^2}$ where, I - Luminous intensity in a given direction. d - Distance between the source and plane E - Illuminance		1 Mark for statement 1 Mark for equation and terms	
1	f)	State the Lux level reco Ans: 1] Class Room – 300 lux	mmended for (1) Class Roo x 2] College Auditoriun	m (2) College Auditorium n - 500 lux	1 Mark for each



Attempt any <u>TEN</u> of the following:

Define Enhance lighting.

**Enhance lighting:** 

1

1 a)

Ans:

20

2 Marks for

(Autonomous)



(ISO/IEC-27001-2013 Certified)

MAHARASHTRA STATE BOARD OF TECHNICAL EDUCATION

# Winter – 2019 Examinations **Model Answers**

Subject & Code: Illumination and Electrification of Buildings (22530)

1 g)	State any two type of lamps used in Horticulture. <b>Ans:</b> i] High pressure sodium lamps ii] Metal halide lamps iii] Any of the standard high pressure lamp of 250W, 500W, 1000W	1 Mark for each of any two = 2 Marks
2	Attempt any <u>THREE</u> of the following:	12
2 a)	<ul> <li>Explain the features of Aquarium lighting.</li> <li>Ans: <ol> <li>The aquarium light depends upon the size of the aquarium tank (Length, width and depth)</li> <li>The aquarium lighting depends upon the all surrounding condition e.g. colour and size of the given hall in which the aquarium is placed.</li> <li>The aquarium lighting depend upon the maintenance schedule of the tank water and other aquarium accessories.</li> <li>The aquarium lighting depends upon the surrounding temperature and required temperature of water in the tank.</li> <li>In some type of aquarium the ultraviolet lamps are provided for the bacteria killing purpose.</li> <li>The aquarium lighting also depends upon the various aquarium accessories used in the tank.</li> </ol> </li> </ul>	1 Mark for each of any four features = 4 Marks
	7) The aquarium lighting should be electrically and mechanically safe to all the type of fishes and operator also.	

- 8) The aquarium lighting should be economical.
- 9) The life of the aquarium lighting should be long.
- Illustrate with neat wiring diagram a single lamp control by two point method. 2 b) Ans:

# Single lamp control by two point method:



2 Marks

2 Marks

This system is commonly used for stair case wiring. It consists of two way switches (the switch operates always in one of the two possible positions) the circuit diagram is as shown in figure above.

Assume that the lamp is in between ground floor and first floor with switch S1 is on ground floor and S2 is on first floor. When the position of the switches S1 & S2 is as shown in figure then the lamps is 'ON'. When a person reaches on first floor the lamp is required to be switched 'OFF' so the person will change the position of switch S2, so that the lamp will be switched 'OFF'.



# Winter – 2019 Examinations **Model Answers** Subject & Code: Illumination and Electrification of Buildings (22530)

2 Explain the working of HPMV Lamp with neat diagram. c) Ans:

# High-pressure Mercury-Vapour Lamp (HPMVL): Working:

- ➤ Whenever 1-ph, 230V, AC Supply is provided to the discharge tube of MVL, initially the current flows from Phase to the choke to the starting electrode to neutral.
- ≻ The starting electrode or resistance is made of tungsten filament having more resistance ( 5 to 10 k $\Omega$ ), so that whenever current flows through the tungsten filament, as per the thermal emission, the light is emitted through the filament. The initial colour of light is therefore blue.



High pressure mercury vapour lamp (HPMV).

- > At the same time the rated voltages is applied in between the main electrode No.1 & main electrode no. 2. Due to this voltage, there will be collision of neon gas particles & current will start to flow through the discharge tube,
- $\triangleright$  Whenever temperature surrounding the inner tube increases up to 600° C the mercury powder will start vaporizing & the continuous collision process of all inert gases takes place so that full light is emitted through the discharge tube.
- > The colour of light is bluish white. The full light is emitted after 10-15 min.

# **OR Student may write**

The construction & connection diagram is as shown in figure. As per this construction there are following components.

Choke: The choke is acting as the ballast. At the time of supply voltage variation, the current flowing through the inner tube is maintained constant to keep uniform light intensity. Sometimes choke can be designed to get the higher voltages, to apply to the inner tube of mercury vapour lamp.

Starting resistance/limiting resistance: Whenever current flows through the starting resistance, there is a  $I^2R$  loss which is converted into heat. If the temperature of this heat goes near about 600° C then inert gases ionization starts.

Auxiliary electrode & Main electrode: It is made by high resistive element. The ionization is takes place through the inert gases whenever current flows from auxiliary electrode to main electrode.

Inner Tube: The various inert gases e.g. Argon, Nitrogen etc with mercury powder are filled in the inner tube at 5 to 7 times of the atmospheric pressure.

Outer Tube: The function of outer tube is to make the vacuum surrounding the inner tube to avoid thermal dissipation or to maintain 600°C surrounding the inner tube.

Power factor improvement Capacitor: The function of power factor improvement capacitor is to improve the power factor from 0.5 to 0.95.

2 Marks for explanation

diagram



# Winter – 2019 Examinations <u>Model Answers</u> Subject & Code: Illumination and Electrification of Buildings (22530)

- 2 d) Compare the AC and DC Arc lamps.
  - Ans:

115.			
AC Arc Lamp	DC Arc Lamp		
Cross section area of electrode is same	Cross section area of electrode is positive rod is twice that of negative rod		
Series inductor is used for stability	Series resistance used for stability		
Voltage required is (39 +2.8 L)V Where L is length of arc in mm	Voltage is required 40V to 60V		
AC supply is used for AC arc lamp	DC supply is used for DC arc lamp		
Luminous efficiency is less	Luminous efficiency is high		

1 Mark for each of any four points = 4 Marks

# **3** Attempt any <u>THREE</u> of the following:

- 3 a) Explain the working of Neon sign tube with diagram. **Ans:** 
  - Neon sign tube:



2 Marks for diagram

12

The construction & circuit diagram for neon tube is as shown in fig. Basically neon tube is used for advertisement or decoration purpose. The maximum length of tube is 8m. The available diameter for neon tubes are 5mm,10mm,15mm, 20mm, 30mm, etc. When the supply is switched on at primary, high voltage is induced in secondary winding of HT transformer. This voltage is applied across electrodes. At this high voltage, a discharge occurs in neon gas. In the neon tube, we can achieve various colours by changing the constituents of the gases and mercury filled in the tube. The choke is used for ballast & power factor improvement capacitor is also used. For the neon tube, continuous high voltage is required, so that following precautions should be taken.

- The neon tube should be installed by government authorized supervisor.
- The metal body of the HT transformer must be earthed separately.
- Caution notice of danger board is required.
- 3 b) State the selection criterion of the lamp for various purposes.

2 Marks for explanation



# Winter – 2019 Examinations Model Answers

Subject & Code: Illumination and Electrification of Buildings (22530)

# Ans:

# Selection criterion of the lamp for various purposes:

While selecting a lamp for a particular purpose, the available lamps are compared on the basis of following criteria:

- Light output
- Input wattage
- Efficacy (lumens per watt)
- Rated service life
- Size
- Surface brightness
- Color characteristics
- Electrical operating characteristics
- Requirement of additional equipment such as ballasts
- Compatibility with the electrical system
- Suitability for the operating environment
- 3 c) State any four design considerations for illumination scheme of commercial complex. Ans:

# Design considerations for illumination scheme of commercial complex:

- Tasks to be performed in the space
- Desired light levels based on the tasks performed in the space
- Room size and dimensions
- Structural obstructions such as beams
- Layout of furniture and obstructions such as partitions
- Room and object surface colors and reflectances
- Special concerns such as safety and security
- Hours of operation
- Assessment of normal operating conditions
- Possibility or known existence of abnormal operating conditions
- Cleanliness of the area during operation
- Maintenance schedule
- Availability of daylight
- 3 d) Describe the working principle of Thyristor operated dimmer with the help of circuit diagram.

#### Ans:

# Thyristor operated dimmer:



2 Marks for circuit diagram

A popular thyristor operated dimmer circuit employ TRIAC-DIAC phase control for

 $\frac{1}{2}$  Mark for each of any eight criteria = 4 Marks

1 Mark for Each of any four design consideration = 4 Marks (Autonomous) (ISO/IEC-27001-2013 Certified)



# Winter – 2019 Examinations <u>Model Answers</u> Subject & Code: Illumination and Electrification of Buildings (22530)

MAHARASHTRA STATE BOARD OF TECHNICAL EDUCATION

low AC power control. During each half-cycle, the capacitor charges through  $(R_1+VR_1)$ . When the capacitor voltage becomes equal to a breakover voltage of diac, the diac conducts. The capacitor then discharges through diac and gate-MT<sub>1</sub> junction of triac. The discharge current provides gate current to triac to turn it on. After turn-on of triac, it acts like short-circuit and supply voltage appears across lamp. For rest of the half-cycle, the supply voltage appears across the lamp. If the triac is fired early in the half-cycle, the supply voltage appears across lamp for longer period and lamp glows brighter. However, if the triac is fired later in the half-cycle, the supply voltage appears across lamp for longer period and lamp glows brighter charging to breakover voltage of diac. i.e charging time constant {C  $(R_1+VR_1)$ }. Thus by reducing VR<sub>1</sub> the lamp brightness can be increased.

OR

# (Any other equivalent circuit diagram using SCR and its explanation)

# 4 Attempt any <u>THREE</u> of the following:

- 4 a) Select the illumination level required as per ISI for following working plane in residential building.
  - (i) Kitchen sink
  - (ii) Staircase
  - (iii) Dining room
  - (iv) Study room

# Ans:

Sr.No	Area	<b>Recommended illumination level</b>
1	Kitchen sink	200 Lux
2	Staircase	60 to 100 Lux
3	Living Room	200 to 300 Lux
4	Dining Room	150 Lux

1 Mark for each = 4 Marks

2 Marks

2 Marks

explanation

12

- 4 b) Explain the lighting scheme to be designed for each of the following:
  - i) Special ward in hospitals
  - ii) Dentist's Cabin

# Ans:

# i) Special ward in hospital:

For the patients in the wards, lighting should create a cozy and pleasant atmosphere. Lighting in the wards should be planned in such a way that it meets the specific requirements of the patients in a ward, for example, some of the patients may like to sleep before the scheduled time of 'lights out' so a high level of illumination will be a nuisance to those patients. Considering all these requirements, the level of illumination of 100 lux is acceptable for general lighting of wards which will also meet the needs of the nursing staff.

Apart from general lighting, individual patients can be provided with additional lights in the form of bed head lights which can be switched 'on' or 'off' by patients themselves. These lights also contribute to the general appearance of the wards by breaking the monotonous uniformity that will result from general lighting.

# ii) Dentist's Cabin:

The right dental lighting should strike a balance between providing enough high

MAHARASHTRA STATE BOARD OF TECHNICAL EDUCATION (Autonomous) (ISO/IEC-27001-2013 Certified)

#### Winter – 2019 Examinations <u>Model Answers</u> at & Code: Illumination and Electrification of Buildin

# Subject & Code: Illumination and Electrification of Buildings (22530)

intensity illumination to enhance work precision, especially when it comes to procedures such as colour matching for restorations and cosmetic work, as well as reducing eye strain and improving energy levels as light can affect how tired you feel at the end of the day.

That blue light is a dental curing light. It's basically a piece of dental equipment that we use to harden or cure our resin or basically, toothcolored filling materials, as well as some other materials that we use such as cements and bonding agents that we use to restore your teeth back to health.

4 c) Analyze the effect of supply voltage on performance of LED as regards current, Lumen output, efficacy and life.

Ans:

- 1) **Effect on Current:-** In LED current depends upon supply voltage, if voltage get changes then current also change but this change in current will be control by resistors which are connected in series.
- 2) **Effect on Lumen output:-** If voltage is increased then brightness of LED get 1 Mark each increased.
- 3) **Effect on Efficacy:-** With fluctuation in supply voltage of LED, the efficacy gets decreased.
- 4) **Effect on Life:-** If supply voltage is not stable then life of LED get reduced.

# 4 d) State the purpose of lighting control. List the different types of dimmer. **Ans:**

# **Purpose of Lighting Control:-**

- 1. To turn ON or OFF the lamps
- 2. For dimming: The dimming control permits the adjustment of lighting over a range.
- 3. For changing the lighting levels according to need or desired of the owner.
- 4. For energy saving.
- 5. To increase the life of lighting source.
- 6. To increase the safety of lighting system.
- 7. In some types of industrial or automation, there is need of lighting control.
- 8. To provide proper lux level on working plane, the lighting control is required.
- 9. To fulfillment light intensity as per Indian or international standard

10. To control the brightness of T.V monitor, there is need of lighting control

# Types of Dimmer :

- 1) Dimmer by using changing resistance (Rheostatic)
- 2) By using auto transformer
- 3) By salt water method
- 4) By two winding transformer tap changing method
- 5) Thyristor or SCR operated dimmer
- 6) Triac operated Dimmer

7) PWM (Pulse width modulation) Controlled technique.

# 4 e) State the different types of outdoor flood lighting and where are they used.

# Ans:

# There are three types of projectors used for flood lighting :

a) Narrow beam Projector



<sup>1</sup>/<sub>2</sub> Mark for

each of any

four

purposes

= 2 Marks

<sup>1</sup>/<sub>2</sub> Mark for

each of any

four dimmers

= 2 Marks







# Winter – 2019 Examinations **Model Answers**

# Subject & Code: Illumination and Electrification of Buildings (22530)

	<ul> <li>b) Medium angle Projector</li> <li>c) Wide angle Projector</li> <li>a) Narrow beam Projectors: -</li> </ul>	1 Mark for each type = 3 Marks
	Light beam with such a projectors spreads between 12° and 25°. They can be employed for a distance of 70 meter.	
	Projectors with beam spread between 25° and 40°. These are employed for a distance of 30-70 meter.	
	A projector with beam spreads between 40° and 90°. They can be employed for a distance of 30 meter or below.	
	<ul> <li>USE:</li> <li>1) It is used to illuminate buildings at night, ancient building and monuments, churches &amp; gardens etc</li> <li>2) It is used for illuminating railway yards, stadiums, car parking area etc.</li> <li>3) It is used for illuminating advertisements, boarding's etc.</li> </ul>	1 Mark for any two uses
5	Attempt any <u>TWO of the following</u> :	12
5 a)	State the various lighting calculations methods and Describe any one of them.	
	Ans: Lighting calculation methods:	
	1. Lumens or Light flux method	2 Marks for
	2. Point to point or Inverse Square law method	methods
	3. Watts per Square meter method	
	i) Lumens or Light flux method: This method is applied where an average illumination is required. Total lumens output is calculated from the efficiency of each lamp and the number of lamps used in the circuit. To calculate lumens received on the working plane, the total lumens already calculated is multiplied by the co-efficient of utilization. When the lamps & the surroundings are not perfectly clean, then while calculating the lumens received on the working plane, the depreciation factor or maintenance factor is taken into consideration, Thus lumens received on working plane =(Number of lamps× wattage of each lamp × efficiency of each lamp × coefficient of utilization) / (depreciation factor)	4 Marks for explanation of any one method

= number of lamps  $\times$  wattage of each lamp $\times$  efficiency of each lamp  $\times$  utilization factor ×maintenance factor

OR

Calculate Total Lumens = 
$$\frac{A \times I \times W}{C \times M.F.}$$

# ii) Point to point or Inverse Square law method:-

This method is applied where the illumination is required at a point due to one or more

(Autonomous)



(ISO/IEC-27001-2013 Certified)

MAHARASHTRA STATE BOARD OF TECHNICAL EDUCATION

# Winter – 2019 Examinations <u>Model Answers</u> Subject & Code: Illumination and Electrification of Buildings (22530)

sources of light. The illumination at any point within the range of lamp can be calculated from the inverse square Law, if a polar curve of lamp and candle power of lamp reflected by its reflector in different directions is known. If two or more lamps are illuminating the same working plane, illumination due to each can be calculated and added. This method is not commonly used due to more complications involved in its calculations. However, It is used in flood lighting & the yard lighting calculations. **iii) Watts per Square meter method:-**

Basically it is a thumb rule method. It is very handy for rough calculation or checking. While applying this method, we allow watts/square meter of area to be illuminated is taken according to the illumination desired on an average value considering overall efficiency of the lighting system.

5 b) A workshop measures 10m ×25m. The shop is illuminated by 24 lamps of 200 watts each. The lumen efficiency of each lamp is 15 lumens per watt. Depreciation factor is assumed to be 0.8 and a co-efficient of utilization of 0.5. Determine the illumination on the working plane.

<b>Data Given:</b> Area of workshop = $10m \times 25m = 250m^2$	1 Mark for area
Total lumen by all lamps = No. of lamps × watt of each lamp × efficiency of each lamp = $24 \times 200 \times 15$ =72000 lumens	2 Marks for total lumens
$\therefore \text{ Lumens utilized} = \frac{Lumens \ produced \times Utilization \ factor}{Depreciation \ factor} = \frac{72000 \times 0.5}{0.8} = 45000 \ lumens$	2 Marks for lumens
: Illumination on the working plane = lumens per area = $45000/250$ = $180 \text{ lumens/m}^2 \text{ or lux.}$	1 Mark for illumination

5 c) State the requirements of illumination scheme of shipyard.

# Ans:

# **Requirements of illumination scheme of shipyard:**

- 1) The shipyard lighting always depends upon the surrounding conditions. e.g. wind pressure, rain fall, location of shipyard from the sea-share etc.
- 2) The shipyard lighting always depends upon the type & capacity of alternator which is held in ship for interior applications and the capacity of alternator which is installed in the ship-yard and any other non-conventional sources installed in that particulars area for all outdoor application.
- 3) In the every shipyard there may be limitation on the conventional sources. To over-come these limitations, sometimes non-conventional sources, e.g. solar, tidal etc are to be used. At the time of illumination design we have to consider this factor.
- 4) We have to consider control room, emergency–control, emergency medical centre, loading and unloading areas etc. in the ship-yard for its standard lux level.
- 5) In every ship-yard, the electrical & mechanical safety is the prime-moto. At the time of illumination design, the all safety precautions are to be taken.
- 6) The life of the shipyard lighting should be always more.

1 Mark for each of any six points = 6 Marks MAHARASHTRA STATE BOARD OF TECHNICAL EDUCATION (Autonomous) (ISO/IEC-27001-2013 Certified)

# Winter – 2019 Examinations Model Answers

### Subject & Code: Illumination and Electrification of Buildings (22530)

- 7) The cost of the ship-yard lighting should be always economical.
- 8) The every ship-yard station should be free from any type of pollution, e.g. water pollution, sound pollution or noise pollution to the commercial communication signals.
- 9) At the time of ship-yard lighting for the outdoor applications, we have consider total area of water, which is covered by the illumination.
- 10) The ship-yard lighting is always at the remote place slightly away from the seashore, so the ship-yard lighting wiring should be easy for replacement.
- 11) The maintenance and the repairing of the shipyard lighting system should be simple & less. The ship-yard lighting should allow the navigation signals and lights to control the various ships.
- 12) In ship-yard lighting the various lamp are used to get the proper lux level and for energy saving purpose. Some of the lamps are forge, Bollards, foot lamps, solar grass lamps, LED-Solar energy lawn lamps, various focus lamps, metal halide lamps etc.

# 6 Attempt any <u>TWO</u> of the following:

6 a) Enlist the luminaries used in factory lighting and lux level required in various areas. **Ans:** 

Sr. No	Area	Luminaries	Lux level
1	Office building	Fluorescent tube, LED, CFL	500 lux
2	Testing centre	Fluorescent tube, LED, CFL	400 to 500 lux
3	Workshop/work place	Halogen lamp, mercury vapour lamp, sodium vapour lamp	Above 5000 lux
4	Research and development center	Fluorescent tube, LED, CFL	500 to 600 lux
5	Outdoor area/parking area	Mercury or sodium vapour lamp	1000 to 2000 lux
6	Quality control department	Fluorescent tube, LED, CFL	600 to 700 lux
7	Sales department	Fluorescent tube, LED, CFL	300 to 400 lux
8	Commissioning department	Fluorescent tube, LED, CFL	400 to 500 lux
9	Small Store Room Without sunlight	Fluorescent tube, LED, CFL, Projector lamp, filament lamp, Halogen Lamp, Metal Halide lamp etc	200-300 Lux
10	Highbay area	Fluorescent tube, LED, CFL, Projector lamp, filament lamp, Halogen Lamp, Metal Halide lamp etc	Above 600 Lux

1 Mark for each of any six areas = 6 Marks

6 b) Describe control of a single lamp from three places. Draw the relevant circuit diagram. Ans:

Single lamp control from three places-

3 Mark for ladder diagram

12



Û

# Winter – 2019 Examinations <u>Model Answers</u> Subject & Code: Illumination and Electrification of Buildings (22530)

It consists of two way switches & intermediate switch, the circuit diagram is as shown in figure. We require two 2-way switches and one intermediate switch and a lamp. Connect all these as shown as in the diagram below. For shown positions of two-way switches, the lamp will glow only if the intermediate switch is in position 2. With these positions of the switches, if position of any one switch is changed, then the lamp will be turned off.



6 c) A drawing hall 30 metres by 15 metres with a ceiling height of 5 metres is to be provided with a general illumination of 120 lumens per m<sup>2</sup>; taking a coefficient of utilization of 0.5 and depreciation factor of 1.4, Determine the number of fluorescent tubes required, their spacing, mounting height and total wattage. Take luminous efficiency of fluorescent tube as 40 lumens per watt for 80 watt tubes. **Ans:** 

(NOTE: Marks should be given step wise for numerical solution of problems.) Data Given:

- I = 120 lumens/m²Area of working plane A = 30 m x 15 m = 450 m²C = 0.5D.F = 1.4Wattage of each lamp = 200 wattEfficiency of lamp = 40 lumens/watt for 80 watt tube.
  - i) Total lumens required on working plane =  $\frac{AIWD}{c} = \frac{450 \times 120 \times 1 \times 1.4}{0.5}$  1 Mark =151200 lumens
  - ii) Total No. of fluorescent tube  $=\frac{Total \ lumens \ given \ out \ by \ lamps}{Wattage \ of \ each \ lamp \ \times luminous \ efficiency} = \frac{151200}{80 \times 40}$ 1 Mark  $= 47.25 \cong 48 \ Nos \ of \ lamp$

The number of lamps can be increased or decreased (46 Lamps or 50 Lamps) for better illumination design.

iii) Total Wattage = Total No. of Lamps x wattage of lamp

2 Marks for

explanation



Winter – 2019 Examinations	
Model Answers	
Subject & Code: Illumination and Electrification of Buildings (22530)	
$= 48 \times 80$	
= 3840 watts	1 Mark
iv) Space & Mounting height:	
∴ Space= 3.75m and mounting height 5m (Widthwise)	
Space-height ratio = $3.75/5 = 0.75$	1 Mark
And Space = 5m and mounting height 5m (Lengthwise)	
Space-height ratio = $5/5 = 1$	
Working plane is assumed as a ground surface	
Arrangements of Fluorescent Tube :	2 Marks
2.5 5m $5m$ $5m$ $5m$ $5m$ $5m$ $2.5$	

